

PRASAR BHARATI  
(INDIA'S PUBLIC SERVICE BROADCASTER)  
DOORDARSHAN KENDRA::GUWAHATI: 781 024.

No. DDK/GHY/AC PLANT/Enquiry/2018-19  
TO

Dated: .08/03/2019

Sub.: Enquiry for the supply of 4mm thickness 150mm $\varnothing$  MS pipe and 3 mm thickness 100mm $\varnothing$  MS Pipe and laying charges of above pipe in between plant and cooling tower (damaged portion) for DDK Guwahati – Reg.

**(THE QUOTATION SHOULD REACH THIS OFFICE ON OR BEFORE 20/03/2019)**

Dear Sir,

This office is interested in replacing damaged portion of MS PIPE 4 mm thickness 150mm  $\varnothing$  size pipe in condenser line from the plant to cooling tower particularly outside portion and 3 mm thickness 100mm  $\varnothing$  size pipe in equalizing line between two cooling tower as proposed by the following

Sr. No.	Specifications	Type of work	Rate in Rs (Lump Sum)
1.	Supply of 4mm thickness, 150 mm diameter pipe of length 100 feet to be replaced in damaged portion of condenser line including proper welding and proper fitting charges.	1job	
2	Supply of 3mm thickness, 100 mm diameter pipe of length 11 feet to be replaced with damaged portion of equaliser line including proper welding, and proper fitting charges.	1 job	
3	Supply of 4 mm thickness, 150 mm diameter bend – 6 nos to be replaced for the damaged bend in condenser line, including fitting charges	1 job	
4	Supply of 4mm thickness, 150 mm diameter flange – 2 no. to be replaced for the damaged flange in condenser line including fitting charges.	1 job	
5	Painting of the above replaced Pipe Section with One Coat of Zinc Primer and Two Coats of good quality enamel Paint.	1 Job	
6		GST @ ____%	
		<b>Grant Total</b>	

**Note: Lowest Tenderer will be considered on the basis of addition of Sl.No 1 to 6, i.e. Grand Total.**

**TERMS AND CONDITION:**

1. The material supplied shall be of reputed make.

Contd...2

..2...

2. The existing damaged pipe to be removed and replace with new pipe in respective places.
3. The cost quoted shall be inclusive of materials and labour charges involved.
4. The agency who intends to participate in the bid may please inspect the site to assess the quantum of work involved before submission of bid.
5. No advance payment shall be made and the agency, on completion of the work shall submit pre receipted bill so that payment shall be made by NEFT/ECS mode.
6. GST Rates as applicable shall clearly be mentioned and the GST Registration certificate shall be enclosed along with the quote.
7. While replacing the pipes with the newly supplied pipes, the Valves and other fixtures associated in the respective lines should be mounted by welding at the appropriate places as in the existing set up.
8. GST compliance bill shall be submitted indicating this office GST number and the HSN code.
9. Copies of PAN card & GST registration shall be enclosed along with the quotation.
10. The quotation shall be opened on 20.03.2019 at 15:00 Hrs .

(J.SRINIVASAN)  
ASSISTANT ENGINEER (STORES)  
For DDG (E) DDK GUWAHATI